


KILOMETER POST SHEET TOTAL

Sompol Chatusrini

E13633

Eva 6-30-03



NOTES I. Fitting and pocket required only where movement can occur between airder and abutment.

Type I conduit-

Caltrans

2. Fill pocket around fitting with resilient waterproof

July I, 1999

The State of California or its officers or agents shall not be responsible for the accuracy or completeness of electronic copies of this plai

50 Tvc


(See Notes)

Copper braid

bonding jumper

Type I conduit Abutment

DETAIL U CONDUIT RISER CONNECTION AT COLUMN OR ABUTMENT



CONDUIT EXPANSION-DEFLECTION FITTING

STATE OF CALIFORNIA DEPARTMENT OF TRANSPORTATION

SIGNAL, LIGHTING AND **ELECTRICAL SYSTEMS ELECTRICAL DETAILS** STRUCTURE INSTALLATIONS

NO SCALE

ALL DIMENSIONS ARE IN MILLIMETERS UNLESS OTHERWISE SHOWN

ES-9B

NOTES

- I. Except for sidewalk joints, a conduit expansion fitting or expansion-deflection fitting shall be installed at each 12 mm or greater structure joint, hinge or abutment.
- 2. Fittings or combination of fittings shall be installed to accommodate the movement rating as shown on the structure plans.
- 3. Fittings shall be installed parallel to superstructure girders.

CONDUIT EXPANSION FITTINGS

- 4. Where lateral movement greater than 6 mm may occur, a neoprene sleeve expansiondeflection fitting shall be installed straddling the joint.
- 5. The external bond strap may be omitted when the fitting is provided with an internal bond equivalent to a No.6 copper bond in Type I conduit or the No.8 equipment grounding conductor in Type 3 conduit.